



## **HALLOWEEN MAZES AT PRIVATE RESIDENCES**

**DATE:** January 17, 2014

**INFORMATION BULLETIN:** F-14-006

**APPROVED BY:** W. Schellhous

A Fire Department permit is not required under the following conditions:

- A. Occupant loads can not exceed a maximum of 49 persons. If occupant load is expected to exceed 49 persons a Fire Department permit will be required.
- B. It is recommended that all combustible materials be flame resistant. Materials that can not be made flame resistant should not be used.
- C. A minimum 2A10BC portable fire extinguisher or a garden hose should be accessible to cover all portions of the maze.
- D. You should ensure that adequate exiting from the maze is provided. It is recommended that exits be a minimum of 32 inches clear.
- E. All extension cords should be heavy duty type and plugged directly into a legal outlet.

Although a Fire Department permit is not required under these conditions, it is your responsibility to ensure you provide a fire safe environment for any persons entering your Halloween maze.

These conditions do not authorize violations or cancellation of any law of the city or other city department requirements.